

| | Zweckverband Iller-Riß-Gruppe Laupheim Bihlafingen | Zweckverband Mühlbachgruppe Obersulmetingen Untersulmetingen | Zweckverband Rottumgruppe Baustetten |
|---------------|---|---|--|
| Härtebereich | hart | hart | hart |
| Gesamthärte | 17,7° dH 3,15 mmol/l | 19,6° dH 3,49 mmol/l | 19,7° dH 3,51 mmol/l |
| Carbonathärte | 15,6° dH | 15,0° dH | 16,9° dH |
| pH-Wert | 7,38 | 7,35 | 7,28 |
| Calcium | 94,5 mg/l | 102 mg/l | 102 mg/l |
| Magnesium | 19,4 mg/l | 22,9 mg/l | 23,5 mg/l |
| Kalium | 1,6 mg/l | 1,7 mg/l | 2,0 mg/l |
| Natrium | 9,3 mg/l | 17,5 mg/l | 10,1 mg/l |
| Chlorid | 15,0 mg/l | 38,0 mg/l | 22,0 mg/l |
| Nitrat | 22,0 mg/l | 39,0 mg/l | 18,0 mg/l |
| Sulfat | 10 mg/l | 20 mg/l | 24,0 mg/l |